

**CALIFORNIA COASTAL COMMISSION**

SAN DIEGO AREA

3111 CAMINO DEL RIO NORTH, SUITE 200

SAN DIEGO, CA 92108-1725

(619) 521-8036

**RECORD PACKET COPY**

Filed: September 28, 1998  
49th Day: November 16, 1998  
180th Day: March 27, 1999  
Staff: DL-SD  
Staff Report: November 18, 1998  
Hearing Date: December 8-10, 1998

REGULAR CALENDAR  
STAFF REPORT AND PRELIMINARY RECOMMENDATION

**Th 86**

Application No.: 6-98-21

Applicant: Mr. &amp; Mrs. James Blackburn

Agent: Walt Crampton

Description: Filling a 94-foot wide, 12-foot high, maximum 18-foot deep sea cave and undercut area at the base of the bluff below an existing single-family residence, with a colored and textured erodible concrete mixture and riprap. This application is a follow-up to an emergency permit granted for the seacave fill.

Zoning Open Space/Recreation  
Plan Designation Open Space/Recreation

Site: Bluff face below 371 Pacific Avenue, Solana Beach, San Diego County.  
APN 263-301-02

Substantive File Documents: City of Solana Beach General Plan and Zoning Ordinance; Walt Crampton, "Submittal of Additional Supporting Documentation for Sea-Cave Infill," September 24, 1998; C.J. Randle, "Sea Cave Report," July 6, 1998; CDP 6-98-21-G; 6-97-159-G; F9818.

---

STAFF NOTES:Summary of Staff's Preliminary Recommendation:

Staff is recommending approval of the proposed seacave fill with special conditions requiring long-term monitoring of the seacave fill, regular maintenance, final plans demonstrating the coloring and texturing process, a waiver of liability, and submittal of other required permits. As conditioned, the project will not have a significant adverse impact on shoreline processes, public access and recreation, or the visual quality of the shoreline because the fill will not encroach beyond the bluff face, will erode consistent with the native bluff material, and will be colored and textured to match the surrounding bluffs.

---

PRELIMINARY STAFF RECOMMENDATION:

The staff recommends the Commission adopt the following resolution:

I. Approval with Conditions.

The Commission hereby grants a permit for the proposed development, subject to the conditions below, on the grounds that the development will be in conformity with the provisions of Chapter 3 of the California Coastal Act of 1976, will not prejudice the ability of the local government having jurisdiction over the area to prepare a Local Coastal Program conforming to the provisions of Chapter 3 of the Coastal Act, and will not have any significant adverse impacts on the environment within the meaning of the California Environmental Quality Act.

II. Standard Conditions.

See attached page.

III. Special Conditions.

The permit is subject to the following conditions:

1. Monitoring Program. PRIOR TO ISSUANCE OF THE COASTAL DEVELOPMENT PERMIT, and within 60 days of Commission action, the applicant shall submit to the Executive Director for review and written approval, a plan prepared by a licensed geologist or geotechnical engineer for a seacave monitoring program which includes the following:

- A. An evaluation of the current condition and performance of the sea cave fill, addressing whether any significant weathering or damage has occurred that would adversely impact the future performance of the plugs.
- B. Current measurements of the distance between the residence and the bluff edge (as defined by PRC Section 13577) at 3 or more locations taken within 60 days of Commission action, and annually thereafter. The locations for these measurements shall be identified through permanent markers, benchmarks, survey position, written description, etc. so that annual measurements can be taken at the same bluff location and comparisons between years can provide information on bluff retreat.
- C. Current measurements of the differential retreat between the natural bluff face and the sea cave plug face, at both "vertical" edges of the sea cave plug face and at 20-foot intervals (maximum) along the top of the sea cave plug face/bluff face

intersection taken within 60 days of Commission action, and annually thereafter. The program shall describe the method by which measurements are taken.

- D. Provisions for taking the measurements called for in Sections B and C above and for conducting the evaluation described in section A above annually, by May 1 of each year for three years beginning on the date of Coastal Commission approval of this permit.
- E. Provisions for submittal of a report to the Executive Director of the Coastal Commission on May 1 of each year for three years beginning May 1, 1999. Each report shall be prepared by a licensed geologist or geotechnical engineer. The report shall contain the measurements and evaluation required in section D above. The report shall also summarize all measurements and provides some analysis of trends, annual retreat or rate of retreat. In addition, each report shall contain recommendations, if any, for necessary changes or modifications to the project. If the seacave plug is found to extend seaward of the face of the natural bluff by more than six (6) inches in any location, the report shall include alternatives and recommendations to remove or otherwise remedy this condition such that no seaward extension of the plug will remain.
- F. Provisions for submission of a report containing the information identified in section E above at 3 year intervals following the last annual report (i.e., the first of these triennial reports to be submitted on May 1, 2004); however, reports shall be submitted in the Spring of any year in which the following event occurs:
  - 1. A 20-year storm event
  - 2. An "El Niño" storm event
  - 3. A major tectonic event magnitude 5.5 or greater affecting San Diego County

Thus reports may be submitted more frequently depending on the occurrence of the above events in any given year.

The permittee shall undertake monitoring in accordance with the approved plan. Any proposed changes to the approved plan shall be reported to the Executive Director. No changes to the plan shall occur without a Coastal Commission approved amendment to this coastal development permit unless the Executive Director determines that no amendment is required.

2. Future Maintenance/Debris Removal. The permittee shall remove all debris deposited on the beach or in the water during and after construction of the shoreline protective devices or resulting from failure or damage of the shoreline protective device. In addition, the permittee shall maintain the permitted seawall in its approved state except to the extent necessary to comply with the requirements set forth below. Maintenance of

the seacave shall include maintaining the color, texture and integrity. Any change in the design of the project or future additions/reinforcement of the seacave beyond minor regrouting or other exempt maintenance as defined in Section 13252 of the California Code of Regulations to restore the seacave to its original condition as approved herein, will require a coastal development permit. However, in all cases, if after inspection, it is apparent that repair and maintenance is necessary, the permittee shall contact the Commission office to determine whether permits are necessary. If at any time after project completion, the sea cave plug is found to extend seaward of the face of the natural bluff by more than six (6) inches in any location, the permittee shall obtain and implement a coastal development permit to remove or other remedy this condition such that no seaward extension of the plug remains.

3. Assumption of Risk: PRIOR TO ISSUANCE OF THE COASTAL DEVELOPMENT PERMIT, and within 60 days of Commission action on this permit, the applicant shall execute and record a deed restriction, in a form and content acceptable to the Executive Director, which shall provide: (a) that the applicant understands that the site may be subject to extraordinary hazard from bluff collapse and erosion and the applicant assumes the liability from such hazards; and (b) the applicant unconditionally waives any claim of liability on the part of the Commission or its successors in interest for damage from such hazards and agrees to indemnify and hold harmless the Commission, its officers, agents, and employees relative to the Commission's approval of the project for any damage due to natural hazards. The deed restriction shall run with the land, binding all successors and assigns, and shall be recorded free of prior liens that the Executive Director determines may affect the enforceability of the restriction.

This deed restriction shall not be removed or changed without a Coastal Commission-approved amendment to this coastal development permit unless the Executive Director determines that no amendment is required.

4. U.S. Army Corps of Engineers Permit. PRIOR TO ISSUANCE OF THE COASTAL DEVELOPMENT PERMIT and within 60 days of Commission action, the permittee shall provide to the Executive Director a copy of a U.S. Army Corps of Engineers permit, or letter of permission, or evidence that no Corps permit is necessary. Any mitigation measures or other changes to the project required through said permit shall be reported to the Executive Director and shall become part of the project. Such modifications, if any, may require an amendment to this permit or a separate coastal development permit.

5. State Lands Commission Review. PRIOR TO ISSUANCE OF THE COASTAL DEVELOPMENT PERMIT and within 60 days of Commission action, the applicant shall obtain a written determination from the State Lands Commission that:

- a) No state lands are involved in the development; or

b) State lands are involved in the development, and all permits required by the State Lands Commission have been obtained; or

c) State lands may be involved in the development, but pending a final determination of state lands involvement, an agreement has been made by the applicant with the State Lands Commission for the project to proceed without prejudice to the determination.

6. Public Rights. By acceptance of this permit, the applicant acknowledges, on behalf of him/herself and his/her successors in interest, that issuance of the permit shall not constitute a waiver of any public rights which may exist on the property. The applicant shall also acknowledge that issuance of the permit and construction of the permitted development shall not be used or construed to interfere with any public prescriptive or public trust rights that may exist on the property.

7. Seacave Fill Surface Treatment Plans. PRIOR TO ISSUANCE OF THE COASTAL DEVELOPMENT PERMIT, and within 60 days of Commission action, the applicant shall submit to the Executive Director for review and written approval, final plans for the seacave fill which describe in detail the construction method and technology utilized for texturing and coloring the fill. Such plans shall confirm, and be of sufficient detail to verify, that the fill color and texture closely matches the adjacent natural bluffs, including provision of a color board indicating the color of the fill material.

The permittee shall undertake the development in accordance with the approved plan. Any proposed changes to the approved plan shall be reported to the Executive Director. No changes to the plan shall occur without a Coastal Commission approved amendment to this coastal development permit unless the Executive Director determines that no amendment is required.

#### IV. Findings and Declarations.

The Commission finds and declares as follows:

1. Detailed Project Description. The proposed project involves filling a 94-foot wide, 12-foot high, maximum 18-foot deep seacave with both riprap and pneumatically placed concrete. There were original two separate caves on the site and undercut areas between and on each side of the two caves. By the time the seacaves and undercut areas were filled, the bluff had eroded to one large cave/undercut area. The seacave is located at the base of an approximately 80 foot high coastal bluff below a lot which contains an existing single-family residence. This permit application is a follow-up to an emergency permit granted on December 24, 1997 to fill the two seacaves (#6-97-156-G) and a subsequent emergency permit granted February 23, 1998 to fill both the caves and the surrounding undercut area at least 3 feet deep and 12 feet high (#6-98-21-G).

The site is located west of Pacific Avenue, south of Cliff Street, in the City of Solana Beach. The City of Solana Beach owns the beach and bluff below the residence.

Construction of the sea cave fill involves clearing the cave of cobbles and loose materials and filling the cave with both riprap and pneumatically placed 3500 psi concrete. The sea cave surface consists of a 12-14 inch thick lean, erodible, colored concrete placed in front of a stronger mixture that incorporates steel matting. The process of plugging and filling with a "leaner" erodible soil-cement mix on the external facade and a "stronger" steel mix internally is intended to allow erosion of the plug to match the rate of natural erosion on the adjacent bluffs. The plug would cease eroding once the 12-14 inches of concrete is gone and the steel is exposed. The external facade of the cave has been colored and textured to match the natural bluff, although the fill material is still curing, and thus is difficult to determine at this time how closely the finished material will match the surrounding bluffs.

Past Commission action on the site includes a construction of a one-story addition to the existing residence approved in May 1981 (CDP #F9818). In December 1997, the Commission approved the temporary placement and removal of 4-5 ton size riprap boulders along the base of the coastal bluff at the subject site (#6-97-133). All of the riprap has been removed from the site at this time.

2. Geologic Stability. Section 30235 of the Coastal Act states, in part:

Revetments, breakwaters, groins, harbor channels, seawalls, cliff retaining walls, and other such construction that alters natural shoreline processes shall be permitted when required to serve coastal-dependent uses or to protect existing structures or public beaches in danger from erosion, and when designed to eliminate or mitigate adverse impacts on local shoreline sand supply...

Section 30253 of the Act states, in part:

New development shall:

- (1) Minimize risks to life and property in areas of high geologic, flood, and fire hazard.
- (2) Assure stability and structural integrity, and neither create nor contribute significantly to erosion, geologic instability, or destruction of the site or surrounding area or in any way require the construction of protective devices that would substantially alter natural landforms along bluffs and cliffs.

Coastal Act Section 30235 acknowledges that seawalls, revetments, cliff retaining walls, groins and other such structural or "hard" solutions alter natural shoreline processes. Thus, such devices are required to be approved only when necessary to protect existing

structures. The Coastal Act does not require the Commission to approve shoreline altering devices to protect vacant land or in conjunction with construction of new development. A shoreline protective device proposed in those situations is likely to be inconsistent with various Coastal Act policies. For example, Section 30253 addresses new development and requires that it be sited and designed to avoid the need for protective devices that would substantially alter natural landforms along bluffs and cliffs.

The proposed development is located at the base of a coastal bluff in the City of Solana Beach. Continual bluff retreat and the formation and collapse of sea caves have been documented in northern San Diego County, including the Cities of Solana Beach and Encinitas. Bluffs in this area are subject to a variety of erosive forces and conditions (e.g., wave action, reduction in beach sand, seacave development). As a result of these erosive forces, the bluffs and blufftop lots in the Solana Beach and Encinitas area are considered a hazard area. Documentation has been presented in past Commission actions concerning the unstable nature of the bluffs in these communities and nearby communities (ref. CDP Nos. 6-93-181/Steinberg, 6-92-212/Wood, 6-92-82/Victor, 6-89-297-G/Englekirk, 6-89-136-G/Adams, and 6-85-396/Swift). In addition, a number of significant bluff failures have occurred along the northern Solana Beach/Encinitas coastline which have led to emergency permit requests for shoreline protection (ref. CDP Nos. 6-93-181/Steinberg, 6-93-131/Richards et al, 6-93-36-G/Clayton, 6-93-024-G/Wood, 6-92-212/Wood, 6-92-167-G/Mallen et. al., 6-92-73-G/Robinson, and 6-91-312-G/Bradley).

Historically, the Commission has approved a number of regular permits for seacave fills similar to the proposed project on the bluffs in Solana Beach (#6-98-29/Bennett; #6-98-25/Stroben; #6-97-1646/Lingenfelder; #6-96-102/Solana Beach & Tennis Club; #6-92-82/Victor; #6-87-391/Childs). As noted above, the Commission recently granted a request for temporary riprap on the beach in front of the subject site and 16 other locations in Solana Beach (CDP Nos. 6-97-125 through 6-97-138; 6-98-2) this past winter. In addition, the Executive Director granted three emergency permits for seacave filling on the bluffs adjacent to the project site to the north (#6-98-13/Johnson; #6-98-9/Hamilton; #6-97-157/Folgnier) and one to the south (#6-98-27/O'Neal) in December 1997 and February 1998.

The geotechnical report submitted with the application provides an evaluation of the condition of the bluffs and coastline in the general area of the project site. The report indicates that mechanisms for sea cliff retreat in this area include undercutting by wave action, storm surf, surge and higher tides. Other factors affecting the rate of bluff retreat include degree of fracturing, jointing, seacave and scour formations, consolidation of sediments, steepness of slope, groundwater and surface water conditions, vegetation or lack of, and intensity of pedestrian and animal traffic. The report states that the rate of sea cliff retreat has been calculated from less than 1 inch to more than 6 inches per year. For the Solana Beach area, the study notes that the lower bluff was calculated to have a retreat rate on the order of 3 inches per year between the years 1968 through 1983.

However, the report notes that it is difficult to predict the exact future and magnitude of bluff retreat that may occur in one year, since severe erosion is generally episodic in nature and depends on the intensity of storms and combined high tides.

Between October 1997 and March 1998 the lack of sand on the beaches and other factors resulted in a number of bluff failures and formation of seacaves along the Solana Beach shoreline. Winter storms removed both beach sand and cobbles in many instances, leaving only the flat wave cut bedrock platform. Because the base of the cliff contact with the bedrock platform is about -2 feet MSL, the base of the bluffs have been exposed to frequent impact from waves and storm surge. The geotechnical report indicates that erosion impact creates seacaves defined along ancient fault and fracture zones.

Although the report indicates that the bluffs will continue to retreat and additional bluff failures are possible, there is no specific evidence that the home itself is jeopardy. The closest portion of the residence is approximately 22 feet from the bluff edge. Thus, in this particular case, Section 30235 of the Coastal Act does not require that the Commission approve a shoreline-altering device. However, although the applicant has not demonstrated that the residence is in jeopardy at this time, failure to fill the sea caves will perpetuate the risk of future bluff failures that could threaten the existing structure, resulting in requests for construction of far more massive upper and lower bluff protection than the proposed project.

The subject seacave is somewhat different in nature than other seacave projects approved in Solana Beach in the past due to the extensive size of the cave and the proposed fill. The subject seacave fill is 94-feet wide, 12-feet high, and up to 18-feet deep. Typically, seacaves fill projects in this area have involved more traditionally "cave-shaped" sites, where the cave is significantly deeper than it is wide or high. The nature of the subject seacave more closely resembles bluff undercutting than a typical "cave".

However, the nature of the fill and the impacts of the project are essentially identical to traditional seacave fill projects. In reviewing requests for shoreline protection, the Commission must assess the need to protect private residential development and the potential adverse impacts to public resources associated with construction of shoreline protection. In numerous past actions, the Commission has found that the filling of sea caves as a preemptive measure has fewer impacts upon coastal resources and access than the construction of seawalls and upper bluff structures, which are frequently required to protect existing structures after the collapse of sea caves (#6-92-82/Victor; #6-87-391/Childs). Construction of a seawall and/or upper bluff protection is associated with a number of adverse impacts to public resources, including loss of the public sandy beach area displaced by the structure, "permanently" fixing the back of the beach, which leads to the narrowing and eventual disappearance of the beach in front of the structure, and a reduction/elimination of sand contribution to the beach from the bluff. Other impacts include sand loss from the beach due to wave reflection and scour, accelerated erosion on



adjacent unprotected properties and the adverse visual impacts associated with construction of shore/bluff protective device on the contrasting natural bluffs.

To address these impacts to shoreline processes, the Commission has developed an in-lieu fee program to provide mitigation for the quantifiable effects of seawalls on the shoreline. The methodology estimates the total quantity of sand necessary to replace: a) the reduction in the beach quality material contributed from the seacliff over the life of the armoring; b) the reduction in beach width which will occur when the landward migration of the beach profile is stopped, over the life of the structure; and c) the reduction in beach area which will occur from the seaward encroachment of the seawall. The methodology uses site specific information provided by the seawall applicant as well as estimates, derived from region-specific criteria, of both the loss of beach material and beach area which could occur over the life of the structure, and of the cost to purchase an equivalent amount of beach quality material and to deliver this material to the beaches in the project vicinity. Once the effects are quantified and the costs totaled, an in lieu fee is paid for use for beach sand replenishment projects as mitigation for impacts of the development on beach sand supply.

However, in contrast to seawall projects, the proposed sea cave plug is set into the bluff face and would not take up a portion of the beach seaward of the bluff face that is currently available for public use. Because the structure would be within the bluff, the accelerated erosion from increased wave reflection and "edge effects" to adjacent properties associated with seawalls are not expected to occur with the proposed project. In addition, as noted above, the proposed sea cave plugging and filling procedure has been designed with a "leaner" soil-cement mix 12-14 inches deep on the external facade and a "stronger" mix internally to allow the plug to erode at the same rate as the adjacent bluffs, at least until the internal steel mat is exposed. Thus, the back of the beach is not permanently fixed in place. Further, the seacave will not prevent the erosion of bluff face material onto the beach via subaerial erosion since it will not cover any portion of the bluff as a seawall or upper bluff work would.

On the other hand, like a seawall, the proposed project will have an adverse impact on shoreline processes in that by reducing the risk of bluff collapse, the sandy material of the bluff will not contribute to the beach as it eventually would if the site were left unprotected and the bluffs allowed to erode naturally. However, this impact is outweighed by the benefits of constructing the proposed sea cave plugs now, as a preventative measure, rather than waiting until collapse of the caves requires construction of a seawall, which, as described above, can cause far more adverse impacts to shoreline sand supply and public access. Thus, the shoreline protection mitigation fee has not typically been applied to seacave fill projects, and has not been attached to this project.

The geotechnical information submitted indicates that it is difficult to determine the exact rate at which the lean concrete mix will erode. Estimates of the life of the erodible mix range from 3 years to 60 years, as the rate of erosion depends both on the strength gain

the mix ultimately achieves, storm conditions, and the presence of beach sand. Approximately twelve inches of erodible mixture is the thickness typically applied to seacave fill projects in Solana Beach to mimic the erosion rate of the natural bluffs. Thus, retreat of the lower bluffs is expected to continue at its current rate, and the proposed project will not fix the back of the beach in the immediate future. However, the erodible mix will eventually wear away, leaving the hard concrete plug extending onto the beach. This plug, if not removed, would function as a seawall in that it would block access and fix the back of the beach. Therefore, in order to find the sea cave fill consistent with Chapter 3 policies of the Coastal Act, the plug must be maintained such that it does not extend seaward of the bluff. If the fill does extend seaward of the bluff, it must be shaved, removed, or otherwise altered to be made flush with the bluff face.

In order to monitor the status of the seacave plug (as proposed by the applicant) and to ensure that the plug continues to function as proposed, thus avoiding future requests for more substantial protective devices, Special Condition #1 has been proposed. Special Condition #1 requires submittal and implementation of a monitoring program to include, at a minimum, periodic measurements of the distance between the bluff edge and the residence, an evaluation of the condition of the plugs (i.e., whether any significant weathering or damage has occurred that would adversely impact the performance of the plugs) and measurements of the distance between the face of the sea cave plug and the bluff face, to ensure the plug material is eroding as designed. The initial "baseline" measurements must be taken within 60 days of Commission action. The reports must be submitted to the Commission yearly for the first three years, then at three-year intervals and/or following any major storm event, whichever is more frequent. The condition requires that should the seacave plug be found to extend seaward of the face of the natural bluff by more than six (6) inches in any location, the report must include alternatives and recommendations to remove or otherwise address this condition.

In addition, Special Condition #2 requires the applicant to be responsible for the general maintenance of the sea cave plugs; for example, the removal of debris deposited on the beach during construction of the plug or damage to the plugs in the future. Minor regrouting or exempt maintenance as defined by Section 13252 of the California Code of Regulations to restore the sea cave plugs to its original condition as approved herein (i.e., color, texture, etc.) shall not require an additional coastal development permit or amendment. However, whenever changes or maintenance on the seacave is proposed, the applicant shall contact the Commission office to determine whether permits are necessary.

In addition, in the event that it is determined through the monitoring report or visual observation that any of the sea cave plugs extend seaward of the face of the natural bluff more than six inches, Special Condition #2 requires that the applicant obtain and implement a coastal development permit to remove the portion extending onto the beach, or to implement other corrective measures. The purpose of this condition is to ensure that the permittee removes any portion of the fill that extends seaward of the bluff face

pursuant to a coastal development permit. If for an unforeseen reason the Coastal Commission refuses to grant such a permit, the permittee should obtain an amendment to this permit. If the protruding portion of the plug is removed, the concrete would not adversely impact sand supply. Should the applicant request more substantial shoreline protection in the future, the Commission would reassess the need and appropriateness of assessing the mitigation fee at that time. Thus, the Commission can be assured that, as conditioned, the proposed project will continue to function as proposed, the fill will be properly maintained and that any adverse impacts to shoreline processes have been mitigated.

Thus, the proposed development has been designed and conditioned to be the least environmentally damaging feasible alternative. Failure to pursue the sea cave fill is likely to result in requests for shoreline and/or upper bluff protection in the future which, if permitted, could have a far greater impact on coastal resources. Although the Commission finds that the sea cave plugs have been designed to minimize the risks associated with their implementation, the Commission also recognizes the inherent risk of shoreline development. The plugs will be subject to wave action and will be surrounded by an eroding bluff. Thus, there is a risk of bluff failure during and after construction of the sea cave fill. In addition, there is a risk of damage to the sea cave fill or damage to property as a result of wave action on the sea cave fill. Given that the applicants have chosen to construct the seawall despite these risks, the applicants must assume the risks. Accordingly, Special Condition #3 requires that the applicants record a deed restriction that evidences their acknowledgment of the risks and that indemnifies the Commission against claims for damages that may be brought by third parties against the Commission as a result of its approval of this permit.

Special Conditions #4 requires the applicant to submit a copy of any required permits from the Army Corps of Engineers, to ensure that no additional requirements are placed on the applicant that could require an amendment to this permit. Because the development has already been constructed, all of the "prior-to-issuance" conditions are required to be satisfied within 60 days of Commission action.

Given the above special conditions, the risk to the bluff top structures will be minimized and future stability assured, without adverse impacts to shoreline sand supply. Therefore, the Commission finds that the subject development, as conditioned, is consistent with Sections 30235 and 30253 of the Coastal Act.

3. Visual Resources. Section 30251 of the Act states, in part:

The scenic and visual qualities of coastal areas shall be considered and protected as a resource of public importance. Permitted development shall be sited and designed to protect views to and along the ocean and scenic coastal areas, to minimize the alteration of natural land forms, to be visually compatible with the character of

surrounding areas, and, where feasible, to restore and enhance visual quality in visually degraded areas...

The proposed development would be located on the face of a coastal bluff immediately adjacent to and at the same level as the existing sandy beach. Sea caves are a fairly prominent feature of the shoreline in this area, and filling the cave has altered the natural appearance of the bluffs. It can take weeks or even months before the material fully cures, and thus it is difficult to tell at this time how well the fill material will blend into the surrounding natural bluffs. Therefore, Special Condition #7 requires the applicant to submit final plans of the method by which the color and texture was applied to the fill material, with a color board indicating the color of the fill material. In addition, since the fill material is designed to erode at the same rate as the surrounding natural bluffs, the project will not result in a plug of concrete extending out from the bluffs onto the beach any time in the near future. Special Condition #2 requires monitoring of the fill to ensure it continues to erode.

There are numerous seacave plugs along the bluffs in Solana Beach. These plugs, while visible, are relatively inconspicuous and do not represent a significant visual blight. The appearance of the proposed project would be consistent with the various existing seacave plugs located in the bluffs along the southern stretch of Solana Beach. Seacave plugs are considerably less visually prominent than traditional seawall projects or riprap revetments. Thus, although the project will have an impact on the appearance of the bluffs, the project must be designed and conditioned to match the surrounding natural bluffs to the maximum extent feasible, thereby reducing potential negative visual impacts to a less than significant level. Therefore, the Commission finds that the subject development is consistent with Section 30251 of the Coastal Act.

4. Public Access. Many policies of the Coastal Act address the provision, protection and enhancement of public access to and along the shoreline, in particular, Sections 30210, 20211, 30212.5, 30221, 30223 and 30252. These policies address maintaining the public's ability to reach and enjoy the water, preventing overcrowding by providing adequate recreational area, protecting suitable upland recreational sites, and providing adequate parking facilities for public use. In addition, Section 30604(c) requires that a specific access finding be made for all development located between the sea and first coastal roadway. In this case, such a finding can be made.

The subject project is located on the bluff formation directly adjacent to a public beach. Although public lateral access is available along the entire stretch of coastline in this area, mostly at low tides, vertical access is available only at a limited number of public accessways. Because of the nature of the topography of the area, with steep, fragile coastal bluffs between the first public roadway and the coastline, and the existing, highly developed pattern of development, the provision of additional vertical public access is not practical at this time. In addition, there is an existing public beach stairway approximately

one block north of the subject site at Tide Park Beach. The proposed sea cave filling will not impact this accessway.

Shoreline protection projects do have the potential to impact existing lateral access along the beach. Structures which fix the back of the beach stop the landward migration of the beach profile while the shoreward edge continues to erode, thereby reducing the amount of dry sandy beach available to the public. In the case of the proposed sea cave filling, the plug material has been designed to erode with the natural bluffs, and thus will not fix the back of the beach.

The City of Solana Beach owns the bluff face and beach on the subject site. Dry, sandy beach is accessible in this area only at lower tides, and thus, the protection of a few feet of beach along the toe of the bluff is more critical in this location than it might be in a location where the beach is wider. This stretch of beach has historically been used by the public for access and recreation purposes. It is possible that public prescriptive rights have been established in this area and will continue to be established in the future. Special Condition #6 acknowledges that the issuance of this permit does not waive any public rights that may exist on the property. The seacave plug may be located on State Lands Property, and as such, Special Condition #5 requires the applicant to obtain any necessary permits or permission from the State Lands Commission to perform the work.

Filling of seacaves can present the potential for impacts to public access and recreation resulting from the construction on the beach. However, in the case of the proposed project, the work has already occurred under an emergency permit. No additional work is proposed. Except for minor maintenance, any other work will require an amendment to this permit or a new coastal development permit. Therefore, as conditioned, the Commission finds that the subject proposal will not result in any significant adverse impacts on beach access or public recreation consistent with Sections 30210, 30211, 30212.5, 30221, 30223 and 30252, pursuant to Section 30604(c) of the Coastal Act.

5. Local Coastal Planning. Section 30604(a) also requires that a coastal development permit shall be issued only if the Commission finds that the permitted development will not prejudice the ability of the local government to prepare a Local Coastal Program (LCP) in conformity with the provisions of Chapter 3 of the Coastal Act. In this case, such a finding can be made.

The subject site was previously in the County of San Diego Local Coastal Program (LCP) jurisdiction, but is now within the boundaries of the City of Solana Beach. The City will, in an likelihood, prepare and submit a new LCP for the area to the Commission for review. Because of the incorporation of the City, the certified County of San Diego Local Coastal Program no longer applies to the area. However, the issues regarding protection of coastal resources in the area have been addressed by the Commission in its review of the San Diego County LUP and Implementing Ordinances. As such, the Commission will continue to utilize the San Diego County LCP documents for guidance

in its review of development proposals in the City of Solana Beach until such time as the Commission certifies an LCP for the City.

In preparation of an LCP, the City of Solana Beach is faced with many of the same issues as the City of Encinitas, located immediately north of Solana Beach, whose LCP was certified by the Commission in March 1995. The City of Encinitas' LCP includes the intent to prepare a comprehensive plan to address the coastal bluff recession and shoreline erosion problems in the City. The plan will include at a minimum, bluff top setback requirements for new development and redevelopment; alternatives to shore/bluff protection such as beach sand replenishment, removal of threatened portions of a residence or the entire residence or underpinning existing structures; addressing bluff stability and the need for protective measures over the entire bluff (lower, mid and upper); impacts of shoreline structures on beach and sand area as well as mitigation for such impacts; impacts for groundwater and irrigation on bluff stability and visual impacts of necessary/required protective structures.

The City of Solana Beach should also address these items in the context of a comprehensive approach to management of shoreline resources. Within the limits of the proposed project development, as conditioned, the project can be found consistent with the Chapter 3 policies of the Coastal Act, and will not prejudice the ability of the City of Solana Beach to complete a certifiable local coastal program. However, these issues of shoreline planning will need to be addressed in a comprehensive manner in the future through the City's LCP certification process.

The project site is designated Open Space Recreation in the City of Solana Beach Zoning Ordinance and General Plan, and was also designated for open space uses under the County LCP. As conditioned, the subject development is consistent with these requirements. Therefore, the Commission finds the proposed development, as conditioned, conforms to all applicable Coastal Act Chapter 3 policies, and the subject development will not prejudice the ability of the City of Solana Beach to complete a certifiable local coastal program.

#### 6. Consistency with the California Environmental Quality Act (CEQA).

Section 13096 of the Commission's Code of Regulations requires Commission approval of Coastal Development Permits to be supported by a finding showing the permit, to be consistent with any applicable requirements of the California Environmental Quality Act (CEQA). Section 21080.5(d)(2)(A) of CEQA prohibits a proposed development from being approved if there are feasible alternatives or feasible mitigation measures available which would substantially lessen any significant adverse effect which the activity may have on the environment.

The proposed project has been conditioned in order to be found consistent with the geologic stability, visual quality and public access policies of the Coastal Act. Mitigation measures, including conditions addressing sea cave monitoring and the color of

construction materials, will minimize all adverse environmental impacts. As conditioned, there are no feasible alternatives or feasible mitigation measures available which would substantially lessen any significant adverse impact which the activity may have on the environment. Therefore, the Commission finds that the proposed project is the least environmentally-damaging feasible alternative and can be found consistent with the requirements of the Coastal Act to conform to CEQA.

STANDARD CONDITIONS:

1. Notice of Receipt and Acknowledgment. The permit is not valid and development shall not commence until a copy of the permit, signed by the permittee or authorized agent, acknowledging receipt of the permit and acceptance of the terms and conditions, is returned to the Commission office.
2. Expiration. If development has not commenced, the permit will expire two years from the date on which the Commission voted on the application. Development shall be pursued in a diligent manner and completed in a reasonable period of time. Application for extension of the permit must be made prior to the expiration date.
3. Compliance. All development must occur in strict compliance with the proposal as set forth below. Any deviation from the approved plans must be reviewed and approved by the staff and may require Commission approval.
4. Interpretation. Any questions of intent or interpretation of any condition will be resolved by the Executive Director or the Commission.
5. Inspections. The Commission staff shall be allowed to inspect the site and the development during construction, subject to 24-hour advance notice.
6. Assignment. The permit may be assigned to any qualified person, provided assignee files with the Commission an affidavit accepting all terms and conditions of the permit.
7. Terms and Conditions Run with the Land. These terms and conditions shall be perpetual, and it is the intention of the Commission and the permittee to bind all future owners and possessors of the subject property to the terms and conditions.





EXHIBIT NO. 1  
APPLICATION NO.  
6-98-21  
Location Map  
California Coastal Commission




SCALE 1"=80'

NOTE:  
Photogrammetry for base map from June 18, 1998,  
during the tidal low, of +0.7 feet, MLLW.

LEGEND

- Approximate location of City of Solana Beach setback from street centerline
- - - Approximate location of Coastal Commission 25-foot setback line from bluff
- - - Approximate location of Coastal Commission 40-foot setback line from bluff
- - - Location of infill
- Limits of seawall/retail/overhang
- Section #
- Location of cross section



22'-10" BLUFF  
TOP  
18" ROOF  
OVERHANG


22'-10" BLUFF  
TOP

6' ROOF  
OVERHANG

371 PACIFIC AVENUE  
BLACKBURN RESIDENCE

Figure No. 1

EXHIBIT NO. 2
APPLICATION NO. 6-98-21
Site Plan
California Coastal Commission



1  
Fig. 1

371 PACIFIC AVE - SECTION

SCALE: 1"=20' (HORIZ.; VERT.)

EXHIBIT NO. 3

APPLICATION NO.  
6-98-21

Profile

California Coastal Commission